



VENDOR DOCUMENT COVER SHEET

Total number of
pages within this document
(including this page)

3 pages

PROJECT: PV GAS THI VAI LPG STORAGE TANKS

PURCHASER'S DOC. No.:

REV:

DOCUMENT TITLE:

Anchor Bolt Detail Drawing

VENDOR DOCUMENT No.:

231375-ME8A-M26-002

REV:

0

PO NUMBER:

LPGTV/PTSC-TH/LOA-03-008

EQUIPMENT TAG

FT-8801A/B

EQUIPMENT DATASHEET

ME8A- FIRE WATER TANKS

SUPPLIERS NAME & ADDRESS:

PTSC THANH HOA TECHNICAL SERVICES
COMPANY

Address: Nghi Son Commune, Nghi Son District, Thanh
Hoa Province

NOTES:

VD CODE No.

M26

REVISIONS TO PURCHASER'S DOCUMENT No.

DOCUMENT STATUS AS REVIEWED BY PURCHASER

Rev	Date	Description	Signature
-----	------	-------------	-----------

A	29-Aug-23	Issued for Review	
---	-----------	-------------------	--

0	08-Sep-23	Issued for Construction	
---	-----------	-------------------------	--

☒ 1 Approved

☐ 2 Approved with comment

☐ 3 Rejected

☐ 4 Information only

Reviewed By:

Date:

COMMENTS RESPONSE SHEET (CRS)

Drawing / Document Number, Title and Revision:

Transmittal Document Purpose:

Doc. No.	231375-ME8A-M26-002	Title:	Anchor bolt detail drawing for Fire Water Tank	Comment	Status
Rev. No.	A			Code	
Transmittal No.:				2	Approved with comment

No.	Comments	Confirmation / Explanation by Contractor
1	Detail: anchor bolt; anchor chair Bolt: Type H (recommended) Min. Embedded length in concrete (type H) = 670mm Anchor bolt length shall consider: Project length; Anchor chair; Bitume sand (80mm); Min. Embedded length in concrete	- Noted. We already changed to H type per comment in next revision.
2	Cập nhật chiều dài bu lông theo CMT bản vẽ GA. Chiều sâu trong bê tông: Min. = 670mm (type H) - Nếu sử dụng Type J, chiều sâu trong Bê tông tham chiều bản vẽ: 231375-02-STD-001.04-Anchor Bolt Detail 1-Rev.0, nếu không có tính toán khác về chiều dài phát triển lực.	Please see reply in item 1



STT	DOCUMENT NUMBER								
REFERENCE DOCUMENTS									
DATE					DATE				
PTSC					PV GAS PMC Deputy General Manager Nguyen Xuan Dong				
O	08/SEP/23	ISSUED FOR CONSTRUCTION	T.C.Thanh	N.V.Phong	N.T.Son	N.K.Dung		B.V.Khoc	
A	29/AUG/23	ISSUED FOR REVIEW	T.C.Thanh	N.V.Phong	N.T.Son	N.K.Dung		B.V.Khoc	
REV.	DATE	DESCRIPTION	ENG.	LEAD	EM	PM	REVIEW	CHKD	
			PTSC				PV GAS PMC		
CLIENT:									
 PETROVIETNAM GAS JOINT STOCK CORPORATION PV GAS PROJECT MANAGEMENT COMPANY									
EPC CONTRACTOR:									
 PETROVIETNAM TECHNICAL SERVICES CORPORATION									
PROJECT:									
PV GAS THI VAI LPG STORAGE TANKS									
PACKAGE:									
ENGINEERING, PROCUREMENT AND CONSTRUCTION									
TITLE:									
DETAIL ANCHOR CHAIR/ BOLT DRAWING FOR FIRE WATER TANK									
JOB.	SCALE	DWG No.					SHEET	REV.	
231375	NTS	231375-ME8A-M26-002					1/1	0	