



VENDOR DOCUMENT COVER SHEET

Total number of
pages within this document
(including this page)

2 pages

PROJECT: PV GAS THI VAI LPG STORAGE TANKS

PURCHASER'S DOC. No.:

REV:

DOCUMENT TITLE:

Detail Nameplate Drawing For Fire Water Tank

VENDOR DOCUMENT No.:

231375-ME8A-M33-001

REV:

1

PO NUMBER:

LPGTV/PTSC-TH/LOA-03-008

EQUIPMENT TAG

FT-8801A/B

EQUIPMENT DATASHEET

ME8A- FIRE WATER TANKS

SUPPLIERS NAME & ADDRESS:

PTSC THANH HOA TECHNICAL SERVICES
COMPANY

Address: Nghi Son Commune, Nghi Son District, Thanh
Hoa Province

NOTES:

VD CODE No.

M33

REVISIONS TO PURCHASER'S DOCUMENT No.

Rev	Date	Description	Signature
A	08-Sep-23	Issued for Review	
0	20-Sep-23	Issued for Construction	
1	16-Oct-23	Issued for Construction	

DOCUMENT STATUS AS REVIEWED BY PURCHASER

- ☐ 1 Approved
- ☐ 2 Approved with comment
- ☐ 3 Rejected
- ☐ 4 Information only

Reviewed By:

Date:

COMMENTS RESPONSE SHEET (CRS)
--

Drawing / Document Number, Title and Revision:

Transmittal Document Purpose:

Doc. No.	231375-ME8A-M33-001	Title:	Detail Nameplate Drawing For Fire Water Tank	Comment	Status
Rev. No.	0			Code	
Transmittal No.:				2	Approved with comment

No.	Comments	Confirmation / Explanation by Contractor
1	EPC CONTRACTOR NAME SHOULE BE ADDED	Noted and Incorporated



1. ALL DIMENSIONS ARE IN MM.
2. LETTERS, FRAME AND STAMPING SQUARES IN THE NAME PLATE SHALL BE EMBOSSED AND THEIR FACES SHALL BE POLISHED BY BUFFING. THE OTHER PART SHALL BE ETCHED 0.2 MM IN DEPTH AND THEN PAINTED AND BAKED WITH BLACK ENAMEL 0.1 MM IN THICKNESS.
3. LETTERS SHALL BE AS FOLLOWS;
 - ; CENTURY BOLD TYPE
 - ; GOTHIC TYPE
4. DATE BUILT SHALL BE STAMPED AS EXAMPLE "2009. 08" AND TO BE STAMPED BY FABRICATOR.
5. MANUFACTURER'S WORK NO. SHALL BE STAMPED IN THE SQUARE OF " SERIAL NO." BY FABRICATOR.
6. CLIENT AND FABRICATOR NAME AND LOGO SHALL BE FILLED LATER ON.
7. OTHER FIRE WATER TANK SHALL HAVE TEMPLATE SAME THIS TANK, JUST DIFFERENT THE TAG NAME FT-8801B

JOB.	SCALE	DWG No.	SHEET	REV.
231375	NTS	231375-ME08A-M33-001	1/1	1